




Controller Model: **Modicon Micro and Momentum**
 Maple OIT Model: **OIT3100 and OIT4100 Series**
 Communication Type: **RS-232 with RJ-45 at PLC**

Use the wiring diagram and illustration to assemble a communication cable for use with a Modicon Micro or Momentum PLC.



OIT END

PLC END

NOTES:

- 1 Install heatshrink on shield (bare wire) to avoid shorting.
- 2 Connect shield wire to the metal housing of the RJ-45 connector.

