



Modbus TCP/IP

Overview

Maple Systems' **Silver Series** Operator Interface Terminals (Maple OITs) communicate with any device that uses the Modbus TCP/IP protocol to allow the Maple OIT to act as the master in a **point-to-point single master, single slave format**.

Note: Single master, single slave signifies that the OIT can only communicate with one Ethernet device. It cannot connect to multiple Ethernet devices.

The MODBUS TCP/IP protocol driver in EZware also has the following features:

- Ability to communicate over Ethernet for 100m
- Ability to communicate over Ethernet at 10 Mbps
- Ability to read/write to individual bits in 3x and 4x memory

Communications Cable

The Maple OIT should be connected to the device's Modbus TCP/IP Ethernet port.

Some controllers require straight through 10baseT Ethernet cables and others require crossover 10baseT Ethernet cables. A list of cables offered by Maple Systems as well as cable assembly instructions to assist you in assembling your own Ethernet cable are available on our website.

WARNING: If your communications cable is not wired exactly as shown in our cable assembly instructions, damage to the OIT or loss of communications can result.

Controller Settings

The Ethernet port on the Controller must be set to Modbus TCP/IP Slave mode in order to properly communicate with the OIT.

Accessible Memory

Register Memory

The following table lists the controller's register memory ranges that the Maple OITs are able to access. Please note that your controller's memory range may be *smaller* or *larger* than that supported by these OITs. The following register memory can be displayed in 16, 32, or 64 bit format on the Maple OIT.

Controller Register Type	Controller Register Description
300001 - 365535	Input Registers, Read Only
400001 - 465535	Holding / Output Registers

Discrete Memory

The following table lists the controller's discrete memory ranges that the Maple OITs are able to access. Please note that your controller's memory range may be *smaller* or *larger* than that supported by these OITs. The following discrete memory is displayable in single-bit format on the Maple OIT.

Controller Bit Type	Controller Bit Description
000001 - 065535	Discrete Coils / Outputs
100001 - 165535	Discrete Inputs, Read Only
3x_Bit (see note)	Bits within Input Registers, Read Only
4x_Bit (see note)	Bits within Holding/Output Registers

NOTE: The 3x_Bit and 4x_Bit memory area is used to read/write to individual bits in the 3x and 4x memory area. To use this feature, select the 3x_Bit or 4x_Bit as **Device Type** for bit-type objects such as Bit Lamps. Under **Device Address**, use the format nnnnbb to enter the word memory area followed by the two digit bit reference. For example, to target the 3rd bit of 400015, enter "1502" into the Device Address, (nn=15, bb=02).

EZware Settings

The following table lists the communications settings that must be configured in EZware. These settings can be found in the Edit-Set System Parameters menu under the PLC tab. Please note:

- the **Recommended Settings** column provides the recommended setting based upon default settings most commonly use in Devices which use Modbus TCP/IP
- the **Options** column lists EZware's options; your controller may not support every option

Name	Recommended Settings	Options	Important Notes
PLC type:	Modbus TCP/IP		

Name	Recommended Settings	Options	Important Notes
Serial port I/F:	Ethernet	RS232, RS485 default, RS485 4W, RS485 2W, Ethernet	Using Modbus TCP/IP requires the use of the Ethernet port.
Data Bits:	n/a	7 or 8	Does not apply to this protocol.
Stop Bits:	n/a	1 or 2	Does not apply to this protocol.
Baud Rate:	n/a	9600,19200, 38400,57600, 115200	Does not apply to this protocol.
Parity:	n/a	Even, Odd, None	Does not apply to this protocol.
HMI station No.:	0	0-255	Use for multiple OITs
PLC station No.:	1	0-255	Must match address of controller port.
Multiple HMI:	Disable	Disable, Master, Slave	Use for multiple OITs
HMI-HMI link speed:	38400	38400, 115200	Use for multiple OITs
Connect I/F:	n/a	Ethernet, Serial	Use for multiple OITs
Local IP Address:	0.0.0.0	XXX.XXX.XXX.XXX	The IP address assigned to the OIT
Server IP Address:	0.0.0.0	XXX.XXX.XXX.XXX	The IP address assigned to the device with which the OIT is communicating
Subnetwork Mask:	255.255.255.0	XXX.XXX.XXX.XXX	A mask for the IP addresses
Default Route IP Address:	0.0.0.0	XXX.XXX.XXX.XXX	Used if the OIT is not directly connected to the device (i.e. through a router)
PLC time out constant (sec)	3.0	1.5 to 5.0	adjust if longer timeout is required
PLC block pack:	0	0-10	Number of words read at one time
Parameter 2	15	0-999	Turn around delay in 0.01 sec